

WAPA COTP Series Capacitor Bank Replacement

EMTP Study

Leopoldo G. Gallegos Jr. Electrical Engineer
Protection



- Background & Objective:
- The California Oregon Transmission Project (COTP) Capacitor Replacement Project (the “Project”) is being implemented because the fixed series capacitor banks (FSCB) on the COTP are fast approaching their 30-year operational life.
- The Project will install a new set of modern fixed series capacitors, associated relays and equipment, including the motor-operated disconnects (MOD).
- It will replace all the existing 525 kV FSCB with new but the same identical capacitor sizes, ratings, two-switching step or segment configuration and maintain the same line series compensation level as the existing one.



System Model:

The 340-mile 525-kV transmission system that will be represented in the EMTP model will consist of the boundary equivalent 525-kV WAPA lines from Tracy – Olinda North. Tracy-Maxwell-Olinda line section is modeled in detail using EMTP’s frequency dependent line model option. At a later point in time the system from Tracy to Los Banos and Tracy to Tesla and Olinda to Captain Jack will be modeled using the frequency dependent line re-build option. Bus work at Tracy and Olinda will be modeled.




Figure 1: System Boundary Equivalent



Purpose of EMTP Simulation:

The EMTP study will have simulations run to determine the energy requirements for the MOV protective devices across the series capacitors at Tracy, Maxwell, and Olinda substations.

The basis for selecting the MOV shall have adequate capability to avoid by-passing the MOV for all external faults with fault durations of 5 cycles or less, also the series capacitors shall not be by-passed during maximum swing current conditions and the protective level of the MOV shall not exceed 2.2 per unit.






Figure 2: EMTP System Boundary Equivalent Model






Figure 3: Tracy Substation modeled in EMTP:



Stray Capacitance Approximation

Table 1: Stray Capacitance Values used in model from tables in Annex B of IEEE C37.011-2019

Location		Steam Turbine (pf)	Surge Arrester (pf)	Outdoor Bushing (pf)	Instrument XFMR (pf)	CCVT (pf)	BUS (pf)	Circuit Breaker (pf)	Disconnect Switches (pf)	Misc (pf)	XFMR			Total (pf)	Total (nf)
A2	VT1A-JT3A,B	0	0	150	600	5825	3537	175	300	50	0			10,637	10.637
B2	VT2A-JT4A,B	0	0	150	600	5825	3537	175	300	50	0			10,637	10.637
A3	JT3A-JT4A	0	0	150	300	0	900	175	300	50	0			1,875	1.875
B3	JT3B-JT4B	0	0	150	300	0	900	175	300	50	0			1,875	1.875
A4	Bus-Breaker	0	0	300	600	0	2700	250	250	50	0			4,150	4.15
B4	Bus-Breaker	0	0	300	600	0	2700	250	250	50	0			4,150	4.15
5	JT6B-JT6C	0	100	600	300	5825	900	1400	1200	150	0			10,475	10.475
6	JT6C-VT6A	0	100	600	300	5825	900	1400	1200	150	0			10,475	10.475



Moving North from Tracy along Tracy to Maxwell is the Line Breaker and Series Capacitor Bank.




Figure 4: Tracy Series Capacitor Bank diagram:






Figure 5: Tracy Series Capacitor Bank EMTP model:



Table 2: Manufacture Provided MOV VI curves

Total Varistor Current Apk	Tracy #1 (PT6B) Varistor Voltage kV pk	Tracy #2 (PT6A) Varistor Voltage kV pk	Maxwell #1 (PT1A) Varistor Voltage kV pk	Maxwell #2 (PT1B) Varistor Voltage kV pk	Olinda S. #1 (PT8B) Varistor Voltage kV pk	Olinda S. #2 (PT8A) Varistor Voltage kV pk	Olinda N. #1 (PT7A) Varistor Voltage kV pk	Olinda N. #2 (PT7B) Varistor Voltage kV pk
200	70.07	108.27	71.54	137.08	70.54	122.02	64.01	115.44
300	70.45	108.85	71.99	137.94	70.94	122.70	64.36	116.08
400	70.72	109.28	72.32	138.61	71.22	123.21	64.62	116.54
500	70.94	109.61	72.59	139.13	71.46	123.63	64.82	116.94
750	71.35	110.24	73.08	140.13	71.91	124.41	65.23	117.67
1000	71.66	110.73	73.47	140.86	72.23	124.98	65.52	118.20
1500	72.11	111.43	74.01	142.13	72.72	125.83	65.95	119.00
2000	72.45	111.95	74.55	143.20	73.08	126.46	66.27	119.58
3000	72.95	112.71	75.36	144.79	73.62	127.40	66.75	120.46
4000	73.32	113.28	75.96	146.01	74.00	128.14	67.10	121.10
5000	73.62	113.75	76.45	146.97	74.41	128.87	67.40	121.77
7500	74.21	114.66	77.36	148.73	75.21	130.27	68.10	123.07
10000	74.76	115.50	78.02	150.02	75.80	131.32	68.64	124.04
15000	75.58	116.78	78.99	152.05	76.70	132.89	69.43	125.51
20000	76.20	117.73	79.80	153.71	77.35	134.01	70.02	126.57
30000	77.11	119.13	81.07	156.34	78.28	135.64	70.86	128.09
40000	77.77	120.14	82.08	158.42	78.98	136.89	71.47	129.23
50000	78.28	120.94	82.93	160.09	79.59	137.99	71.98	130.24



Segment 1 Ratings:

$$I_{RATED} := 2850 \text{ A} \quad \text{Arms}$$

$$V_{RATED} := (I_{RATED} \cdot 9 \ \Omega) = (25.65 \cdot 10^3) \text{ V} \quad V_{rms}$$

$$V_{CREST} := V_{RATED} \cdot \sqrt{2} = (36.275 \cdot 10^3) \text{ V} \quad V_{peak}$$

$$MCOV := 1.1 \cdot V_{RATED} = (28.215 \cdot 10^3) \text{ V} \quad \text{Maximum Continuous Operating Voltage}$$

$$MCOV_{Peak} := MCOV \cdot \sqrt{2} = (39.902 \cdot 10^3) \text{ V}$$

$$PLV := V_{CREST} \cdot 2.2 = (79.804 \cdot 10^3) \text{ V} \quad \text{Protective Level}$$

Current-Voltage characteristic

Desired Voltage rating V RMS

Data Voltage rating V RMS

Current (A) - Voltage (V) matrix

200	70070
300	70450
400	70720
500	70940
750	71350
1000	71660
1500	72110
2000	72450
3000	72950
4000	73320
5000	73620
7500	74210
10000	74700

Voltage multiplier


Current multiplier

Minimum current value

Figure 6: VI input for EMTP's ZnO Data Function tool



Below is the EMTP test circuit that was used to compare EMTP's modeled arrester with manufactures MOV VI values. The curve below in figure 4 shows that EMTP's model is within an acceptable range.



$v_A := 77770 \text{ kV}$ GE MOV kV @ 40kA
 $v_E := 78530 \text{ kV}$ EMTP Simulation kV@ 40kA

$$\delta := \left| \frac{v_A - v_E}{v_E} \right| = 0.968\% \quad \text{Percent Error}$$





Figure 7: Zno Test Circuit and MPLLOT Verification



Line Modeling Using Standard Conductor Data:



Module: Line Model

Units: English

Input option: Standard Conductor data

Use Database

Conductor Data

Number of conductors (wires): 4

Wire	Phase Number	DC resistance [Ohm/mile]	Outside diameter [inches]	Horizontal distance [ft]	Vertical Height at tower [ft]	Vertical Height at Midspan [ft]
1	1	0.0654	1.345	17	55	55
2	2	0.0654	1.345	-17	55	55
3	3	0.0654	1.345	17	86	86
4	0	3.715	0.495	-5	117	117

Additional data for Wire 1

Skin effect correction

Thick/Diam 0.3732

None

Solid conductor

Galloway Wedepohl

Bundled Conductor

Number of conductors in the bundle: 3

Spacing (in): 18

Angular position (deg): 90

Relative permeability: 1

Figure 8: Archived Tower Geometry and EMTP's Line Data Tool



Line Modeling Using EMTP's Line Rebuild Tool.

Enter ASPEN data in per unit, 100 MVA base:				section length (miles)	
sec 1	R1 =	0.00001	X1 =	0.00023	1.192
	R0 =	0.00018	X0 =	0.00086	
sec 2	R1 =	0.00074	X1 =	0.01675	87.247
	R0 =	0.01311	X0 =	0.06276	
sec 3	R1 =	0.00019	X1 =	0.00452	22.703
	R0 =	0.00415	X0 =	0.01476	
sec 4	R1 =	0.00003	X1 =	0.00060	3.026
	R0 =	0.00058	X0 =	0.00182	
sec 5	R1 =		X1 =		
	R0 =		X0 =		
TOTAL	R1 =	0.00097	X1 =	0.02210	114.168
	R0 =	0.01802	X0 =	0.08020	
p.u. per mile at each end					
B1 =	1.3366E-03	B2 =	1.3366E-03	(Y12)	
B10 =	8.8300E-04	B20 =	8.8300E-04	(Y12)	
p.u. total at each end					
B1 =	1.5260E-01	B2 =	1.5260E-01	(Y12)	
B10 =	1.0081E-01	B20 =	1.0081E-01	(Y12)	
calculated primary values in ohms					
R1 =	2.67356	X1 =	60.91313		
R0 =	49.66763	X0 =	221.05125		
calculated primary values in ohms/mile					
R1 =	2.24292	X1 =	51.10161		
R0 =	41.66747	X0 =	185.44568		
calculated ohms/mile and mH/mile at 60 Hz					
	Ω /mile		mH/mile		
R0 =	41.66747	X0 =	491.90994		
R1 =	2.24292	X1 =	135.55124		
shunt admittance in per unit (Y12)					
B10 =	1.0081E-01	B20 =	1.0081E-01		
B1 =	1.5260E-01	B2 =	1.5260E-01		
calculated primary values in Siemens (mhos)					
B10 =	3.6575E-05	B20 =	3.6575E-05		
B1 =	5.5365E-05	B2 =	5.5365E-05		
Siemens (mhos)/mile					
B10 =	3.0684E-05	B20 =	3.0684E-05		
B1 =	4.6447E-05	B2 =	4.6447E-05		
calculated values in uF/mile					
B10 =	8.1391E-02	B20 =	8.1391E-02		
B1 =	1.2321E-01	B2 =	1.2321E-01		
calculated values in uF/mile					
B10 total =	1.6278E-01	I0 charge	22.1724	amp/mile	18.6010
B1 total =	2.4641E-01	I1 charge	33.5633	amp/mile	28.1571
records for tweaking					
tweak	ASPEN	10000	EMTP	10000	% error
R1	2.674		2.81		5.10
X1	60.913		61.45		0.88
R0	49.668		35.93		27.66
X0	221.051		237.87		7.61
total % error					41.25

Figure 9: Excel Spread Sheet to go from ASPEN OneLiner to EMTP Line Rebuild



Line Modeling Using Line Rebuild Tool (Cont.):

Module	Line Model
Units	English
Input option	Conductor data for Line Rebuild
Conductor Data	
Number of Phases	3
R zero sequence [Ohm/mile]	41.667
L zero sequence [mH/mile]	491.90994
G zero sequence [S/mile]	0
C zero sequence [microF/mile]	1.6278E-01
R positive sequence [Ohm/mile]	2.24292
L positive sequence [mH/mile]	135.55121
G positive sequence [S/mile]	0
C positive sequence [microF/mile]	2.4641E-01
Frequency [Hz]	60
DC resistance [Ohm/mile]	0.0




Figure 10: Line Rebuild input and WAPA's test circuit



MOV Energy dissipation:

Below is the method for obtaining the duty cycle and maximum continuous operating voltage of a surge arrester that will withstand a continuous voltage corresponding to the 4,300 Amps 30 minute rating of the capacitor bank:

$I_{E_TCY_1} := 4300 \text{ A}$ Emergency Rating of Tracy Segment 1 Capacitor Bank

$V_{TCY_1_MCOV} := I_{E_TCY_1} \cdot 9 \Omega = (38.7 \cdot 10^3) \text{ V}$

The corresponding MCOV at 38.7-kV from Table 1 of ANSI C62.11 is 39-kV with a duty cycle of 48-kV. This rating matches the existing MOV, therefore the existing MOV VI curve provided by GE was used as a starting point in the EMTP simulation to find the energy dissipated during various faults. The main 2 faults of concern are an internal line fault and an external line fault. If the fault occurs within the section of transmission line where the series cap is located, it is referred to as an internal fault. Anywhere the fault occurs outside of that is an external fault. An internal fault would result in fast or instantaneous clearing time and an external fault in COTP's case will also have high-speed tripping 5 cycles.



External 3 phase to ground fault 5 cycles (83 ms) on Tracy - Maxwell 525-kV transmission line. Bypass breaker logic disabled. The case simulated is an external fault on the Line side of the Tracy series capacitor bank. All COTP series caps are included and the COTP reactor banks are excluded.

Fault occurs at 100ms

Line Breakers clear the fault at 183ms






Figure 11: Phase A current through segment 1 of Tracy series capacitor bank






Figure 12: Phase A current through segment 1 of Tracy MOV






Figure 13: Phase A voltage across segment 1 of Tracy series capacitor bank






Figure 14: Phase A voltage across segment 1 of Tracy MOV






Figure 14: Energy dissipation of segment 1 Tracy MOV Approximately 129MJ



Simulation with Bypass logic enabled




Figure 15: Existing Tracy series capacitor bank protection for triggered air gap & bypass logic






Figure 16: Phase A current through segment 1 of Tracy series capacitor bank with Bypass logic enabled






Figure 17: Phase A current through segment 1 of Tracy MOV with Bypass logic enabled






Figure 18: Phase A voltage across segment 1 of Tracy series capacitor bank with Bypass logic enabled






Figure 19: Phase A voltage across segment 1 of Tracy MOV with Bypass logic enabled






Figure 20: Energy dissipation of segment 1 Tracy MOV Approximately 5.3MJ with bypass logic enabled.



Summary:

- The methods and model presented will be used to evaluate the MOV energy dissipation at the other 3 substation in the WAPA COTP corridor.
- The data obtained will be provided to the manufacture to provide the best fitting MOV and Series CAP protection.



Questions?



Leopoldo G. Gallegos Jr.
gallegos@wapa.gov



www.wapa.gov



@westernareapowr



western-area-power-administration



WesternAreaPower1



westernareapower



wapa.gov

